

Caernarvon Township Authority

601 Hemlock Rd.

Morgantown PA. 19543

DEP Max Contamination Levels (MCL)

mg/L = PPM

Copper

1.3 mg/L

Lead

0.015 mg/L

PPM is part per Million

	No Concern/No Trace	Light Trace	Small trace	Medium Trace	Needs Attention
Percent	0%	Under 25% MCL	Under 50% MCL	Over 50% MCL	Over MCL

Site ID:	Service Address	Copper Result	Lead Result
401	9 Maple Dr.	<0.01	<0.001
402	101 Maple Dr.	0.301	<0.001
404	122 Maple Dr.	0.082	<0.001
406	131 Maple Dr.	0.517	<0.001
407	134 Maple Dr.	0.065	<0.001
408	170 Maple Dr.	0.488	<0.001
410	10 Morlyn Ct.	0.714	<0.001
414	90 Welsh Ln	0.258	0.008
416	3 Center Ave.	0.11	<0.001
417	8 Center Ave.	0.199	<0.001
418	120 Mill Rd	0.295	<0.001
419	113 Mill Rd	0.529	<0.001
424	7 Center Ave.	0.467	<0.001
425	3809 Main St.	0.279	0.002
426	3316 Main St	0.484	<0.001
427	3507 South St.	0.157	<0.001
428	3095 Main St.	0.56	<0.001
429	3411 North St.	0.098	<0.001
430	3414 South St.	0.104	<0.001
431	261 Willow Glen Rd.	0.134	<0.001